## COMMONWEALTH OF KENTUCKY

## BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF FARMDALE WATER	)
DISTRICT FOR A DEVIATION FROM THE	) CASE NO.
REQUIREMENTS OF 807 KAR 5:066, SECTION	2003-00497
4(4), REGARDING WATER STORAGE	)

## ORDER

On December 22, 2003, the Farmdale Water District ("Farmdale District") applied for permission to deviate from Administrative Regulation 807 KAR 5:066, Section 4(4), which requires that each utility maintain minimum water storage of one day's supply of its average daily usage. Farmdale District states in its application that its average daily water usage, including unaccounted-for water, is approximately 604,500 gallons, and that its current water storage capacity is 378,000 gallons. The Frankfort Plant Board, Farmdale District's current water supplier, has a 500,000-gallon water storage tank located near Farmdale's master meter. All water is fed to the master meter by gravity flow. Frankfort Plant Board has assured by letter the availability of water storage for all customers including Farmdale District until March 18, 2008.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Farmdale District is not in compliance with Administrative Regulation 807 KAR 5:066, Section 4(4).

2. Because of the time needed to plan, finance, and construct water storage facilities, Farmdale District should be given until March 18, 2008 to comply with Administrative Regulation 807 KAR 5:066, Section 4(4).

## IT IS THEREFORE ORDERED that:

- 1. Farmdale District is given until March 18, 2008 to comply with the provisions of Administrative Regulation 807 KAR 5:066, Section 4(4).
- 2. Farmdale District shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to March 18, 2008.
- 3. Farmdale District shall file with the Commission a statement confirming that the city of Frankfort continues to provide the storage required by 807 KAR 5:066, Section 4(4), or a report noting the status of the utility's efforts to comply with said regulation prior to March 18, 2007.

Done at Frankfort, Kentucky, this 13<sup>th</sup> day of February, 2004.

By the Commission

ATTEST:

Executive Director